



CERTIFICATE

Sto SE & Co. KGaA

Ehrenbachstraße 1 · D-79780 Stühlingen


have voluntarily subjected their product

StoLook Decor Fine
StoLook Decor Medium

to inspection and testing according to the

TÜV SÜD Test Standard TM 10
“Dispersion interior plasters Issue 01-2022”

The examination has furnished proof that the standard mentioned above is fulfilled in its entirety.



Sto SE & Co. KGaA are granted the right to use the TÜV Mark >> Low emission, Pollutant tested and Production monitored << according to contract.

This certificate is valid until 31.08.2028

Certificate-Nr. TM-10 / 250904-1

Munich, 04.09.2025

Gabriele Glomsda
Department Analytical Chemistry



Add value.
Inspire trust.

TÜV SÜD Industrie Service GmbH · Ridlerstrasse 65 · 80339 Munich · Germany

Sto SE & Co. KGaA
Ehrenbachstrasse 1

79780 Stühlingen
Germany

Your reference/letter of	Our reference/name	Tel. extension/Email	Fax extension	Date	Page
	IS-USL-MUC/ Holger Struwe	+49 89 5791-2636 holger.struwe@tuvsud.com	+49 89 5791-2229	2025-09-04 KT_StoLook Decor Fine-Medium 09- 2025_EN.docx	1 of 1

Evaluation of the emission characteristics and toxic and environmentally relevant constituents of StoLook Decor Fine / - Medium

On behalf of Sto SE & Co. KGaA, TÜV SÜD Industrie Service GmbH tested a sample of the spray plaster **StoLook Decor Fine / - Medium** regarding the criteria for the award of the TM-10 TÜV mark, "Low-emission, Pollutant tested and Production monitored". The results are described in detail in Test Report No. 25-S1428-39, dated 04.09.2025.

The results can be summarised as follows:

- Solvent-free according to VdL-RL-01 (VOC content < 700 mg/kg)
- Plasticizer-free according to VdL-R-L01 (plasticizer content < 700 mg/kg)
- Formaldehyde-free according to VdL-RL-01 (free formaldehyde < 2 mg/kg)
- Formaldehyde emissions tested according to AgBB (28th day value: < 10 µg/m³)
- CMR emissions tested according to AgBB (28th day value: < 1 µg/m³)
- Low emissions tested according to AgBB (28th day value: TVOC < 300 µg/m³)
- No heavy metals (the proportion of substances with bioavailability lies within the limits set by standard EN 71-3)

StoLook Decor Fine / - Medium meets the stringent criteria of TÜV SÜD's test standard TM-10 "dispersion interior plasters", Version 01-2022.

Yours faithfully,

(Dipl.-Ing. (FH) Holger Struwe)
Project leader building products

(Dr. Maria Wagenstaller)
Technical expert building products

Headquarters: Munich
Trade Register Munich HRB 96869
VAT ID No. DE129484218
Information pursuant to § 2 [1] DL-InfoV
(Germany) at tuvsud.com/imprint

Supervisory Board:
Walter Reithmaier (Chairman)
Board of Management:
Simon Kellerer (CEO)
Thomas Kainz
Ferdinand Neuwieser
Paula Pias Peleteiro

TÜV SÜD Industrie Service GmbH
Abteilung Chemische Analytik
Ridlerstrasse 65
80339 Munich
Germany
Phone: +49 89 5791-2206

tuvsud.com/de-is
Hotline: +49 89 5190-4001

TÜV®